Annexure-C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. JAL/2024/344 Dated: 13/04/2024

It is certified that an inspection team headed by Mahesh Kumar –Senior Manager(JAL)

(Name of Officers with designation) from Greater Noida Industrial Development Authority

(PHED/Municipality) Inspected the Bethany Convent School, HS-11C, Sector- Delta-II, Greater

Noida, Distt- Gautam Buddha Nagar, Uttar Pradesh (Name & Address of the school) on

12/04/2024 (date of inspection) and on the basis of Water Test Report (Attached) bearing no

W-190923-01 dated 21/09/2023 of Sri Ram Testing Laboratory –Greater Noida-Distt-G.B.

Nagar-U.P. (PHED Lab) certified that the Bethany Convent School, HS-11 C, Sector- Delta-II,

Greater Noida, Distt- Gautam Buddha Nagar, Uttar Pradesh (Name of school) has safe

drinking water facilities for the students and members of staff of the institution. School is also

maintains the hygienic sanitation condition in the school building & the campus as per norms

prescribed by the Central/ State/ U.T. Govt.

This certificate is valid from to 13/04/2024 to 12/04/2027(03 Years).

Senior Manager (JAL)
Greater Noida Industrial
Development Authority
AGREETER Noida-G.B. Nagar-U.P.

Signature with Seal:

Name

: Mahesh Kumar

Designation

Senior Manager(JAL)

Greater Noida Industrial Development Authority

Greater Noida-G.B. Nagar -U.P.

Name& Address of the Office/Department: 5

То

The Manager

Bethany Convent School,

HS-11 C, Delta-II, Greater Noida,

Distt-Gautam Buddha Nagar (U.P.)

(Name & Address of the Institution)

1 | Page



SHREE RAM TESTING LABORATORIES

ISO 14001: 2015 & ISO 9001: 2015 Approved Laboratory

Lab: A-2/103, Site-V, UPSIDC Industrial Area, Kasna, Greater Noida-201306
H.O. 223, 2nd Floor, Living Style Mall, Jasola, New Delhi-110025
Mob: 9953984801, 9717160780, 9999024801, E-mail: stl.noida@gmail.com
E-mail: info@shreeramlab.com, shreeramlab@yahoo.com, Website: www.shreeramlab.in

TEST REPORT

Issued to: M/S Bethany Convent School. HS-11C, Sector- Delta-II, Greater Noida.

 Report No.
 W-190923-01

 Report date:
 21/09/2023

 Sample Received:
 19/09/2023

 Analysis date:
 19/09/2023 to 21/09/2023

 Sampled By:
 SRTL

Sample Description: Drinking Water (RO)

P- 1/1

Received Sample in Sealed and marked Plastic Bottle.

RESULT

Drinking Water-Essential Tests as per IS 10500:2012

S.No.	Parameters (Units)	Test Method	Results	Requirement as per IS: 10500-2012
1.	Odour	IS:3025(P-5) 2018	Unobjectionable	Unobjectionable
2.	Taste CARONATORIES	IS:3025(P-8) 1984 (RA- 2017)	Agreeable	Agreeable
3.	Colour (Hazen)	IS:3025(P-4) 2021	<1.0	5 max
4.	Turbidity (NTU)	IS:3025(P-10) 1984 (RA- 2017)	Nilaggeres	1 max
5.	pH value (at 25°C)	IS:3025(P-11) 1983 (RA- 2017)	6.5	6.5 to 8.5
6.	Total Dissolved solids (mg/l)	IS:3025(P-16) 1984 (RA- 2017)	22	500 max
7.	Total Hardness (as CaCO ₃) (mg/l)	IS 3025 P-21:2009 (RA- 2019)	8.0	200 max
8.	Chloride (as Cl)) (mg/l)	IS:3025(P-32) 1988 (RA- 2019)	15.27	250 max
9.	Iron (as Fe) (mg/l)	IS:3025(P-53) 2003 (RA- 2019)	0.001	0.3 max
10.	Residual Free Chlorine(mg/l)	IS:3025(P-26) 2021	Nil	0.20 max
11.	Fluoride (as F) (mg/l)	APHA 4500 (D)	0.008	1.0 max
12.	Total Alkalinity (as CaCO ₃), (mg/l)	IS:3025(P-23)- 1986 (RA- 2019)	SHREEN SHREEN	200 max
13.	Magnesium (as Mg), (mg/l)	IS:3025(P-46)- 1994 (RA- 2019)	1.2	30 max
14.	Aluminium (as Al), (mg/l)	IS:3025(P-55)- 2003 (RA- 2019)	Not Detected	0.03 max
15.	Zinc (as Zn), (mg/l)	IS:3025(P-49)- 1994 (RA- 2019)	0.042	5 max
16.	Lead (as Pb), (mg/l)	IS:3025(P-47)- 1994 (RA- 2019)	Not Detected	0.01 max
17.	Mercury (as Hg), (mg/l)	IS:3025(P-48)- 1994 (RA- 2019)	Not Detected	0.001 max
18.	Total Arsenic (as As), (mg/l)	IS:3025(P-37)- 1988 (RA- 2019)	Not Detected	0.01 max
19.	MICROBIOLOGICAL PARAMETERS		SHALL RA	MITESTING LABORA
I	Coliform (cfu/100ml)	IS 1622:1981 (RA- 2019)	Absent	0 max
li	E. Coli (cfu/100ml)	IS 1622:1981 (RA-2019)	Absent	0 max

Remark: The Tested Parameters meet as per BIS specification.

TESTED BY

END OF REPORT

